



## EC DECLARATION OF CONFORMITY

**Enphase Energy INC.**  
 47281 BAYSIDE PARKWAY  
 FREMONT CA  
 United States

This declaration of conformity is issued under the sole responsibility of the manufacturer.

### Q-RELAY-1P-INT

The object of the declaration described above is in conformity with the relevant Union harmonization legislation:

EN 50065-1:2011	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 1: General requirements, frequency bands and electromagnetic disturbances
EN 50065-2-2: 2003 + A1: 2005 + AC:2006	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 2-2: Immunity requirements for mains communications equipment and systems operating in the range of frequencies 95 kHz to 148,5 kHz and intended for use in industrial environments
EN 61000-3-11: 2019	Electromagnetic compatibility (EMC). Limits. Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated voltage current $\leq 75$ A and subject to conditional connection.
EN 61000-3-12: 2011 + AC: 2013	Electromagnetic compatibility (EMC). Limits. Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current $> 16$ A and $\leq 75$ A per phase.
EN 61326-1: 2013	Electrical equipment for measurement, control and laboratory use. EMC requirements. General requirements.
EN 61010-1:2010	Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 1: General requirements.

EMC directive - 2014/30/EU

LOW VOLTAGE directive - 2014/35/EU

**Signed on behalf of Enphase Energy INC.**

01 Jul. 22  
 Fremont, United States

DocuSigned by:  
  
 Karen Maxwell  
 EDC9571FABF94EA...

Karen Maxwell  
 Vice President, Quality



## EU-KONFORMITÄTSERKLÄRUNG

**Enphase Energy INC.**  
 47281 BAYSIDE PARKWAY  
 FREMONT CA  
 United States

Die alleinige Verantwortung für die Ausstellung dieser Konformitätserklärung trägt der Hersteller.

### Q-RELAY-1P-INT

Das beschriebene Produkt und Gegenstand der Erklärung erfüllt die einschlägigen Harmonisierungsrechtsvorschriften der Union:

EN 50065-1:2011	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 1: General requirements, frequency bands and electromagnetic disturbances
EN 50065-2-2: 2003 + A1: 2005 + AC:2006	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 2-2: Immunity requirements for mains communications equipment and systems operating in the range of frequencies 95 kHz to 148,5 kHz and intended for use in industrial environments
EN 61000-3-11: 2019	Electromagnetic compatibility (EMC). Limits. Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated voltage current $\leq 75$ A and subject to conditional connection.
EN 61000-3-12: 2011 + AC: 2013	Electromagnetic compatibility (EMC). Limits. Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current $> 16$ A and $\leq 75$ A per phase.
EN 61326-1: 2013	Electrical equipment for measurement, control and laboratory use. EMC requirements. General requirements.
EN 61010-1:2010	Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 1: General requirements.

EMC directive - 2014/30/EU

LOW VOLTAGE directive - 2014/35/EU

**Unterzeichnet für und im Namen von:**  
**Enphase Energy INC.**

1. Juli 2022  
 Fremont, United States

DocuSigned by:  
  
 EDC9571FABF94EA...  
 Karen Maxwell  
 Vice President, Quality



## EU-CONFORMITEITSVERKLARING

**Enphase Energy INC.**  
 47281 BAYSIDE PARKWAY  
 FREMONT CA  
 United States

**Verklaren onder onze eigen verantwoordelijkheid dat het product met identificatie:**

### Q-RELAY-1P-INT

Het hierboven beschreven voorwerp is in overeenstemming met de desbetreffende harmonisatiewetgeving van de Unie

EN 50065-1:2011	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 1: General requirements, frequency bands and electromagnetic disturbances
EN 50065-2-2: 2003 + A1: 2005 + AC:2006	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 2-2: Immunity requirements for mains communications equipment and systems operating in the range of frequencies 95 kHz to 148,5 kHz and intended for use in industrial environments
EN 61000-3-11: 2019	Electromagnetic compatibility (EMC). Limits. Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated voltage current $\leq 75$ A and subject to conditional connection.
EN 61000-3-12: 2011 + AC: 2013	Electromagnetic compatibility (EMC). Limits. Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current $> 16$ A and $\leq 75$ A per phase.
EN 61326-1: 2013	Electrical equipment for measurement, control and laboratory use. EMC requirements. General requirements.
EN 61010-1:2010	Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 1: General requirements.

EMC directive - 2014/30/EU

LOW VOLTAGE directive - 2014/35/EU

**Ondertekend voor en namens:**  
**Enphase Energy INC.**

1 juli 2022  
 Fremont, United States

DocuSigned by:  
  
 Karen Maxwell  
EDC9571FABF94EA...

Karen Maxwell  
 Vice President, Quality



## DICHIARAZIONE DI CONFORMITÀ UE

**Enphase Energy INC.**  
 47281 BAYSIDE PARKWAY  
 FREMONT CA  
 United States

La presente dichiarazione di conformità è rilasciata sotto la responsabilità esclusiva del fabbricante.

### Q-RELAY-1P-INT

L'oggetto della dichiarazione di cui sopra è conforme alla pertinente normativa di armonizzazione dell'Unione:

EN 50065-1:2011	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 1: General requirements, frequency bands and electromagnetic disturbances
EN 50065-2-2: 2003 + A1: 2005 + AC:2006	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 2-2: Immunity requirements for mains communications equipment and systems operating in the range of frequencies 95 kHz to 148,5 kHz and intended for use in industrial environments
EN 61000-3-11: 2019	Electromagnetic compatibility (EMC). Limits. Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated voltage current $\leq 75$ A and subject to conditional connection.
EN 61000-3-12: 2011 + AC: 2013	Electromagnetic compatibility (EMC). Limits. Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current $> 16$ A and $\leq 75$ A per phase.
EN 61326-1: 2013	Electrical equipment for measurement, control and laboratory use. EMC requirements. General requirements.
EN 61010-1:2010	Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 1: General requirements.

EMC directive - 2014/30/EU

LOW VOLTAGE directive - 2014/35/EU

Firmato a nome e per conto di  
**Enphase Energy INC.**

1 luglio 2022  
 Fremont, United States

DocuSigned by:  
  
 EDC9571FABF94EA...

Karen Maxwell  
 Vice President, Quality



## DÉCLARATION UE DE CONFORMITÉ

**Enphase Energy INC.**  
 47281 BAYSIDE PARKWAY  
 FREMONT CA  
 United States

La présente déclaration de conformité est établie sous la seule responsabilité du fabricant.

### Q-RELAY-1P-INT

Objet de la déclaration décrit ci-dessus est conforme à la législation d'harmonisation de l'Union applicable:

EN 50065-1:2011	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 1: General requirements, frequency bands and electromagnetic disturbances
EN 50065-2-2: 2003 + A1: 2005 + AC:2006	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 2-2: Immunity requirements for mains communications equipment and systems operating in the range of frequencies 95 kHz to 148,5 kHz and intended for use in industrial environments
EN 61000-3-11: 2019	Electromagnetic compatibility (EMC). Limits. Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated voltage current $\leq 75$ A and subject to conditional connection.
EN 61000-3-12: 2011 + AC: 2013	Electromagnetic compatibility (EMC). Limits. Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current $> 16$ A and $\leq 75$ A per phase.
EN 61326-1: 2013	Electrical equipment for measurement, control and laboratory use. EMC requirements. General requirements.
EN 61010-1:2010	Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 1: General requirements.

EMC directive - 2014/30/EU

LOW VOLTAGE directive - 2014/35/EU

Signé par et au nom de:  
**Enphase Energy INC.**

1er juillet 2022  
 Fremont, United States

DocuSigned by:  
  
 EDC9571FABF94EA...  
 Karen Maxwell  
 Vice President, Quality



## DEKLARACJA ZGODNOŚCI UE

**Enphase Energy INC.**  
 47281 BAYSIDE PARKWAY  
 FREMONT CA  
 United States

Niniejsza deklaracja zgodności wydana zostaje na wyłączną odpowiedzialność producenta.

### Q-RELAY-1P-INT

Wymieniony powyżej przedmiot niniejszej deklaracji jest zgodny z odnośnymi wymaganiami unijnego prawodawstwa harmonizacyjnego:

EN 50065-1:2011	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 1: General requirements, frequency bands and electromagnetic disturbances
EN 50065-2-2: 2003 + A1: 2005 + AC:2006	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 2-2: Immunity requirements for mains communications equipment and systems operating in the range of frequencies 95 kHz to 148,5 kHz and intended for use in industrial environments
EN 61000-3-11: 2019	Electromagnetic compatibility (EMC). Limits. Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated voltage current $\leq 75$ A and subject to conditional connection.
EN 61000-3-12: 2011 + AC: 2013	Electromagnetic compatibility (EMC). Limits. Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current $> 16$ A and $\leq 75$ A per phase.
EN 61326-1: 2013	Electrical equipment for measurement, control and laboratory use. EMC requirements. General requirements.
EN 61010-1:2010	Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 1: General requirements.

EMC directive - 2014/30/EU

LOW VOLTAGE directive - 2014/35/EU

**Podpisano w imieniu:**  
**Enphase Energy INC.**

1er juillet 2022  
 Fremont, United States

DocuSigned by:  
  
 EDC9571FABF94EA...

Karen Maxwell  
 Vice President, Quality



## DECLARACIÓN UE DE CONFORMIDAD

**Enphase Energy INC.**  
 47281 BAYSIDE PARKWAY  
 FREMONT CA  
 United States

La presente declaración de conformidad se expide bajo la exclusiva responsabilidad del fabricante.

### Q-RELAY-1P-INT

El objeto de la declaración descrita anteriormente es conforme con la legislación de armonización pertinente de la Unión:

EN 50065-1:2011	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 1: General requirements, frequency bands and electromagnetic disturbances
EN 50065-2-2: 2003 + A1: 2005 + AC:2006	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 2-2: Immunity requirements for mains communications equipment and systems operating in the range of frequencies 95 kHz to 148,5 kHz and intended for use in industrial environments
EN 61000-3-11: 2019	Electromagnetic compatibility (EMC). Limits. Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated voltage current $\leq 75$ A and subject to conditional connection.
EN 61000-3-12: 2011 + AC: 2013	Electromagnetic compatibility (EMC). Limits. Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current $> 16$ A and $\leq 75$ A per phase.
EN 61326-1: 2013	Electrical equipment for measurement, control and laboratory use. EMC requirements. General requirements.
EN 61010-1:2010	Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 1: General requirements.

EMC directive - 2014/30/EU

LOW VOLTAGE directive - 2014/35/EU

Firmado en nombre de:  
**Enphase Energy INC.**

01 July 2022  
 Fremont, United States

DocuSigned by:  
  
 Karen Maxwell  
 EDC9571FABF94EA...  
 Karen Maxwell  
 Vice President, Quality



## DECLARAÇÃO UE DE CONFORMIDADE

**Enphase Energy INC.**  
 47281 BAYSIDE PARKWAY  
 MV 's-Hertogenbosch  
 The Netherlands

A presente declaração de conformidade é emitida sob a exclusiva responsabilidade do fabricante

### Q-RELAY-1P-INT

O objeto da declaração acima descrito está em conformidade com a legislação de harmonização da União aplicável:

EN 50065-1:2011	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 1: General requirements, frequency bands and electromagnetic disturbances
EN 50065-2-2: 2003 + A1: 2005 + AC:2006	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 2-2: Immunity requirements for mains communications equipment and systems operating in the range of frequencies 95 kHz to 148,5 kHz and intended for use in industrial environments
EN 61000-3-11: 2019	Electromagnetic compatibility (EMC). Limits. Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated voltage current $\leq 75$ A and subject to conditional connection.
EN 61000-3-12: 2011 + AC: 2013	Electromagnetic compatibility (EMC). Limits. Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current $> 16$ A and $\leq 75$ A per phase.
EN 61326-1: 2013	Electrical equipment for measurement, control and laboratory use. EMC requirements. General requirements.
EN 61010-1:2010	Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 1: General requirements.

EMC directive - 2014/30/EU

LOW VOLTAGE directive - 2014/35/EU

Assinado por e em nome de:  
**Enphase Energy INC.**

01 July 2022  
 Fremont, United States

DocuSigned by:  
  
 Karen Maxwell  
 Vice President, Quality  
 EDC9571FABF94EA...



## EC DECLARATION OF CONFORMITY

**Enphase Energy INC.**  
 47281 BAYSIDE PARKWAY  
 FREMONT CA  
 United States

This declaration of conformity is issued under the sole responsibility of the manufacturer.

### Q-RELAY-3P-INT

The object of the declaration described above is in conformity with the relevant Union harmonization legislation:

EN 50065-1:2011	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 1: General requirements, frequency bands and electromagnetic disturbances
EN 50065-2-2: 2003 + A1: 2005 + AC:2006	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 2-2: Immunity requirements for mains communications equipment and systems operating in the range of frequencies 95 kHz to 148,5 kHz and intended for use in industrial environments
EN 61000-3-11: 2019	Electromagnetic compatibility (EMC). Limits. Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated voltage current $\leq 75$ A and subject to conditional connection.
EN 61000-3-12: 2011 + AC: 2013	Electromagnetic compatibility (EMC). Limits. Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current $> 16$ A and $\leq 75$ A per phase.
EN 61326-1: 2013	Electrical equipment for measurement, control and laboratory use. EMC requirements. General requirements.
EN 61010-1:2010	Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 1: General requirements.

EMC directive - 2014/30/EU

LOW VOLTAGE directive - 2014/35/EU

**Signed on behalf of Enphase Energy INC.**

01 Jul. 22  
 Fremont, United States

DocuSigned by:  
  
 EDC9571FABF94EA...  
 Karen Maxwell  
 Vice President, Quality



## EU-KONFORMITÄTSERKLÄRUNG

**Enphase Energy INC.**  
 47281 BAYSIDE PARKWAY  
 FREMONT CA  
 United States

Die alleinige Verantwortung für die Ausstellung dieser Konformitätserklärung trägt der Hersteller.

### Q-RELAY-3P-INT

Das beschriebene Produkt und Gegenstand der Erklärung erfüllt die einschlägigen Harmonisierungsrechtsvorschriften der Union:

EN 50065-1:2011	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 1: General requirements, frequency bands and electromagnetic disturbances
EN 50065-2-2: 2003 + A1: 2005 + AC:2006	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 2-2: Immunity requirements for mains communications equipment and systems operating in the range of frequencies 95 kHz to 148,5 kHz and intended for use in industrial environments
EN 61000-3-11: 2019	Electromagnetic compatibility (EMC). Limits. Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated voltage current $\leq 75$ A and subject to conditional connection.
EN 61000-3-12: 2011 + AC: 2013	Electromagnetic compatibility (EMC). Limits. Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current $> 16$ A and $\leq 75$ A per phase.
EN 61326-1: 2013	Electrical equipment for measurement, control and laboratory use. EMC requirements. General requirements.
EN 61010-1:2010	Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 1: General requirements.

EMC directive - 2014/30/EU

LOW VOLTAGE directive - 2014/35/EU

Unterzeichnet für und im Namen von:  
**Enphase Energy INC.**

1. Juli 2022  
 Fremont, United States

DocuSigned by:  
  
 Karen Maxwell  
 EDC9571FABF94EA...  
 Karen Maxwell  
 Vice President, Quality



## EU-CONFORMITEITSVERKLARING

**Enphase Energy INC.**  
 47281 BAYSIDE PARKWAY  
 FREMONT CA  
 United States

**Verklaren onder onze eigen verantwoordelijkheid dat het product met identificatie:**

### Q-RELAY-3P-INT

Het hierboven beschreven voorwerp is in overeenstemming met de desbetreffende harmonisatiewetgeving van de Unie

EN 50065-1:2011	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 1: General requirements, frequency bands and electromagnetic disturbances
EN 50065-2-2: 2003 + A1: 2005 + AC:2006	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 2-2: Immunity requirements for mains communications equipment and systems operating in the range of frequencies 95 kHz to 148,5 kHz and intended for use in industrial environments
EN 61000-3-11: 2019	Electromagnetic compatibility (EMC). Limits. Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated voltage current $\leq 75$ A and subject to conditional connection.
EN 61000-3-12: 2011 + AC: 2013	Electromagnetic compatibility (EMC). Limits. Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current $> 16$ A and $\leq 75$ A per phase.
EN 61326-1: 2013	Electrical equipment for measurement, control and laboratory use. EMC requirements. General requirements.
EN 61010-1:2010	Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 1: General requirements.

EMC directive - 2014/30/EU

LOW VOLTAGE directive - 2014/35/EU

**Ondertekend voor en namens:**  
**Enphase Energy INC.**

1 juli 2022  
 Fremont, United States

DocuSigned by:  
  
 EDC9571FABF94EA...  
 Karen Maxwell  
 Vice President, Quality



## DICHIARAZIONE DI CONFORMITÀ UE

**Enphase Energy INC.**  
 47281 BAYSIDE PARKWAY  
 FREMONT CA  
 United States

La presente dichiarazione di conformità è rilasciata sotto la responsabilità esclusiva del fabbricante.

### Q-RELAY-3P-INT

L'oggetto della dichiarazione di cui sopra è conforme alla pertinente normativa di armonizzazione dell'Unione:

EN 50065-1:2011	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 1: General requirements, frequency bands and electromagnetic disturbances
EN 50065-2-2: 2003 + A1: 2005 + AC:2006	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 2-2: Immunity requirements for mains communications equipment and systems operating in the range of frequencies 95 kHz to 148,5 kHz and intended for use in industrial environments
EN 61000-3-11: 2019	Electromagnetic compatibility (EMC). Limits. Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated voltage current $\leq 75$ A and subject to conditional connection.
EN 61000-3-12: 2011 + AC: 2013	Electromagnetic compatibility (EMC). Limits. Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current $> 16$ A and $\leq 75$ A per phase.
EN 61326-1: 2013	Electrical equipment for measurement, control and laboratory use. EMC requirements. General requirements.
EN 61010-1:2010	Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 1: General requirements.

EMC directive - 2014/30/EU

LOW VOLTAGE directive - 2014/35/EU

Firmato a nome e per conto di  
**Enphase Energy INC.**

1 luglio 2022  
 Fremont, United States

DocuSigned by:  
  
 Karen Maxwell  
 EDC9571FABF94EA...  
 Karen Maxwell  
 Vice President, Quality



## DÉCLARATION UE DE CONFORMITÉ

**Enphase Energy INC.**  
 47281 BAYSIDE PARKWAY  
 FREMONT CA  
 United States

La présente déclaration de conformité est établie sous la seule responsabilité du fabricant.

### Q-RELAY-3P-INT

Objet de la déclaration décrit ci-dessus est conforme à la législation d'harmonisation de l'Union applicable:

EN 50065-1:2011	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 1: General requirements, frequency bands and electromagnetic disturbances
EN 50065-2-2: 2003 + A1: 2005 + AC:2006	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 2-2: Immunity requirements for mains communications equipment and systems operating in the range of frequencies 95 kHz to 148,5 kHz and intended for use in industrial environments
EN 61000-3-11: 2019	Electromagnetic compatibility (EMC). Limits. Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated voltage current $\leq 75$ A and subject to conditional connection.
EN 61000-3-12: 2011 + AC: 2013	Electromagnetic compatibility (EMC). Limits. Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current $> 16$ A and $\leq 75$ A per phase.
EN 61326-1: 2013	Electrical equipment for measurement, control and laboratory use. EMC requirements. General requirements.
EN 61010-1:2010	Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 1: General requirements.

EMC directive - 2014/30/EU

LOW VOLTAGE directive - 2014/35/EU

Signé par et au nom de:  
**Enphase Energy INC.**

1er juillet 2022  
 Fremont, United States

DocuSigned by:  
  
 EDC9571FABF94EA...  
 Karen Maxwell  
 Vice President, Quality



## DEKLARACJA ZGODNOŚCI UE

**Enphase Energy INC.**  
 47281 BAYSIDE PARKWAY  
 FREMONT CA  
 United States

Niniejsza deklaracja zgodności wydana zostaje na wyłączną odpowiedzialność producenta.

### Q-RELAY-3P-INT

Wymieniony powyżej przedmiot niniejszej deklaracji jest zgodny z odnośnymi wymaganiami unijnego prawodawstwa harmonizacyjnego:

EN 50065-1:2011	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 1: General requirements, frequency bands and electromagnetic disturbances
EN 50065-2-2: 2003 + A1: 2005 + AC:2006	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 2-2: Immunity requirements for mains communications equipment and systems operating in the range of frequencies 95 kHz to 148,5 kHz and intended for use in industrial environments
EN 61000-3-11: 2019	Electromagnetic compatibility (EMC). Limits. Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated voltage current $\leq 75$ A and subject to conditional connection.
EN 61000-3-12: 2011 + AC: 2013	Electromagnetic compatibility (EMC). Limits. Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current $> 16$ A and $\leq 75$ A per phase.
EN 61326-1: 2013	Electrical equipment for measurement, control and laboratory use. EMC requirements. General requirements.
EN 61010-1:2010	Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 1: General requirements.

EMC directive - 2014/30/EU

LOW VOLTAGE directive - 2014/35/EU

Podpisano w imieniu:  
**Enphase Energy INC.**

1er juillet 2022  
 Fremont, United States

DocuSigned by:  
  
 Karen Maxwell  
 EDC9571FABF94EA...  
 Karen Maxwell  
 Vice President, Quality



## DECLARACIÓN UE DE CONFORMIDAD

**Enphase Energy INC.**  
 47281 BAYSIDE PARKWAY  
 FREMONT CA  
 United States

La presente declaración de conformidad se expide bajo la exclusiva responsabilidad del fabricante.

### Q-RELAY-3P-INT

El objeto de la declaración descrita anteriormente es conforme con la legislación de armonización pertinente de la Unión:

EN 50065-1:2011	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 1: General requirements, frequency bands and electromagnetic disturbances
EN 50065-2-2: 2003 + A1: 2005 + AC:2006	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 2-2: Immunity requirements for mains communications equipment and systems operating in the range of frequencies 95 kHz to 148,5 kHz and intended for use in industrial environments
EN 61000-3-11: 2019	Electromagnetic compatibility (EMC). Limits. Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated voltage current $\leq 75$ A and subject to conditional connection.
EN 61000-3-12: 2011 + AC: 2013	Electromagnetic compatibility (EMC). Limits. Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current $> 16$ A and $\leq 75$ A per phase.
EN 61326-1: 2013	Electrical equipment for measurement, control and laboratory use. EMC requirements. General requirements.
EN 61010-1:2010	Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 1: General requirements.

EMC directive - 2014/30/EU

LOW VOLTAGE directive - 2014/35/EU

Firmado en nombre de:  
**Enphase Energy INC.**

01 July 2022  
 Fremont, United States

DocuSigned by:  
  
 Karen Maxwell  
 EDC9571FABF94EA...

Karen Maxwell  
 Vice President, Quality



## DECLARAÇÃO UE DE CONFORMIDADE

**Enphase Energy INC.**  
 47281 BAYSIDE PARKWAY  
 FREMONT CA  
 United States

A presente declaração de conformidade é emitida sob a exclusiva responsabilidade do fabricante

### Q-RELAY-3P-INT

O objeto da declaração acima descrito está em conformidade com a legislação de harmonização da União aplicável:

EN 50065-1:2011	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 1: General requirements, frequency bands and electromagnetic disturbances
EN 50065-2-2: 2003 + A1: 2005 + AC:2006	Signaling on low-voltage electrical installations in the frequency range 3 kHz to 148,5 kHz - Part 2-2: Immunity requirements for mains communications equipment and systems operating in the range of frequencies 95 kHz to 148,5 kHz and intended for use in industrial environments
EN 61000-3-11: 2019	Electromagnetic compatibility (EMC). Limits. Limitation of voltage changes, voltage fluctuations and flicker in public low-voltage supply systems, for equipment with rated voltage current $\leq 75$ A and subject to conditional connection.
EN 61000-3-12: 2011 + AC: 2013	Electromagnetic compatibility (EMC). Limits. Limits for harmonic currents produced by equipment connected to public low-voltage systems with input current $> 16$ A and $\leq 75$ A per phase.
EN 61326-1: 2013	Electrical equipment for measurement, control and laboratory use. EMC requirements. General requirements.
EN 61010-1:2010	Safety requirements for electrical equipment for measurement, control, and laboratory use - Part 1: General requirements.

EMC directive - 2014/30/EU

LOW VOLTAGE directive - 2014/35/EU

Assinado por e em nome de:  
**Enphase Energy INC.**

01 July 2022  
 Fremont, United States

DocuSigned by:  
  
 Karen Maxwell  
 EDC9571FABF94EA...

Karen Maxwell  
 Vice President, Quality