

MANUFACTURERS DECLARATION OF CONFORMITY (DoC) FOR IQBATTERY-5P-1P-NA**Manufacturer:**

Enphase Energy, Inc.,
47281 Bayside Parkway,
Fremont, CA, 94538,
United States of America

This declaration of conformity is issued under the sole responsibility of the manufacturer.

Enphase IQ Battery 5P (SKU: IQBATTERY-5P-1P-NA) is an all-in-one AC-coupled Battery Energy Storage System (BESS) with a total usable energy capacity of 5.0 kWh and a 3.84 kVA continuous power rating. Each IQ Battery 5P includes six embedded grid-forming IQ8D-BAT microinverters (SKU: IQ8D-BAT-240). The IQ Battery 5P product datasheet can be found at <https://enphase.com/download/iq-battery-5p-data-sheet>.

The IQ8D-BAT microinverters comply with UL 1741 SB per the certificate of compliance (Certificate number 20231030-E341165), which can be found in Annex 1.


Declaration:

The IQ Battery 5P (SKU: IQBATTERY-5P-1P-NA) utilizes six IQ8D-BAT (SKU: IQ8D-BAT-240) microinverters for power conversion. Each power conversion unit in the battery that interfaces with the AC utility grid is UL1741 SB compliant. Therefore, the IQ battery 5P is UL1741 SB compliant. The product datasheet confirms compliance with IEEE 1547:2018 (UL 1741-SB, 3rd Ed.).

Signed for and on behalf of Enphase Energy, Inc.

Sangam Baligar

Director- WW Compliance



March-14-2024

Fremont, United States

CERTIFICATE OF COMPLIANCE

Certificate Number 20231030-E341165
Report Reference E341165-20230315
Date 2023-10-30

Issued to: ENPHASE ENERGY, INC.
1420 N McDowell Blvd Petaluma, CA 94954-6515
United States

This is to certify that Permanently-Connected, Grid Support Interactive, Supporting
representative samples of Energy Storage, Multimode, Bi-directional Microinverter
Model: IQ8D-BAT-240, IQ8D-BAT

Have been investigated by UL in accordance with the Standard(s)
indicated on this Certificate.


Standard(s) for Safety: See Page 2

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL
Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and
covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz,
Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL.
For questions, please contact a local UL Customer Service Representative at <http://ul.com/about-us/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20231030-E341165
Report Reference E341165-20230315
Date 2023-10-30

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Standards for Safety:

UL 1741, Inverters, Converters, Controllers and Interconnection System Equipment for Use With Distributed Energy Resources, Edition 3, Issue Date 09/28/2021, Revision Date 10/18/2022. Including the requirements in UL 1741 Supplement A (SA) and B (SB).

IEEE 1547, Interconnection and Interoperability of Distributed Energy Resources (DERs) with Associated Electric Power Systems (EPSs) Interfaces, Issue Date 02/15/2018

IEEE 1547.1, IEEE Standard Conformance Test Procedures for Interconnecting Distributed Energy Resources (DERs) with Electric Power Systems (EPSs) Associated Interfaces, Issue Date 03/05/2020.

UL 62109-1, Safety of Converters for Use in Photovoltaic Power Systems - Part 1: General Requirements, Edition 1, Revision Date 04/30/2019; IEC 62109-2, Safety of Power Converters for use in Photovoltaic Power Systems - Part 2: Particular Requirements for Inverters, Edition 1, Issue Date 06/2011.


CSA C22.2 No. 62109-2, Safety of Power Converters for Use in Photovoltaic Power Systems - Part 2: Particular Requirements for Inverters, Edition 1, Issue Date 07/2016.

CSA C22.2 No. 62109-1, Safety of Power Converters for Use in Photovoltaic Power Systems - Part 1: General Requirements, Edition 1, Issue Date 07/2016.

☒ R21: The evaluation to the Standards above provides evidence of compliance to the intent of the existing California Rule 21 Interconnection. See Appendix A (Method SA and SB).

☐ 14H (SA): The evaluation to the Standards above provides evidence of compliance to HECO Rule 14H, SRD V1.0, Interconnection Application.

☒ 14H (SB): The evaluation to the Standards above provides evidence of compliance to HECO Rule 14H, SRD V2.0, Interconnection Application.



Bruce Mahrenholz,
Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL.
For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutus/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20231030-E341165
Report Reference E341165-20230315
Date 2023-10-30

Inverter Firmware Version:			
Model	UL 1998 (grid support)	Date	Version/Revision
IQ8D-BAT-240, IQ8D-BAT	Yes	2023-03-06	4.31.01
IQ8D-BAT-240, IQ8D-BAT	Yes	2023-05-19	4.35.01
IQ8D-BAT-240, IQ8D-BAT	Yes	2023-10-30	4.36.01



Bruce Mahrenholz,
 Director North American Certification Program
 UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL.
 For questions, please contact a local UL Customer Service Representative at <http://ul.com/about/locations/>.



CERTIFICATE OF COMPLIANCE

Certificate Number 20231030-E341165
Report Reference E341165-20230315
Date 2023-10-30


Appendix A

As permitted by UL1741, 3rd Edition, Table SA1.1, shown below, allows for the evaluation of products using either the UL 1741 SA tests or alternative testing methods using the requirements of IEEE 1547.1-2020 in accordance with IEEE 1547-2018 and IEEE 1547a-2020.

UL1741 SA Test Name	SA Test Section	Comparable IEEE 1547.1-2020 and UL1741 SB Test Section	Subject Inverter complies with SA/IEEE 1547.1-2005
Anti-Islanding Protection	SA8	5.10.2	Pass
Low and High Voltage Ride-Through	SA9	5.4.4, 5.4.7	Pass
Low and High Frequency Ride-Through	SA10	5.5.3, 5.5.4	Pass
Normal Ramp Rates	SA11.2	NA ^a	Pass
Soft-Start Ramp Rates	SA11.4	5.6	Pass
Specified Power Factor	SA12	5.14.3	Pass
Volt/Var Mode	SA13	5.14.4	Pass
Frequency-Watt	SA14	5.15.2	Pass
Volt-Watt	SA15	5.14.9	Pass
Disable Permit Service	SA17	5.6	Pass
Limit Active Power	SA18	5.13	Pass
For the purpose of Grid Support Interactive evaluations, this table provides options to use tests from either the UL 1741 SA or IEEE 1547.1 2020 and UL1741SB.			
^a IEEE 1547-2018 and IEEE 1547.1-2020 do not have a requirement for, or test equivalent to, the UL 1741 SA Normal Ramp Rate which is presently a local requirement per California Rule 21 and/or Hawaii 14H which both require compliance with the Normal Ramp Rate test of SA11.2. Additional testing to SA11.2 Normal Ramp Rate has been conducted to demonstrate compliance on this DER.			

For Volt/Var Mode (clause 5.14.4 of IEEE 1547.1-2020):

Functional in the following priority modes: ☐ active power ☒ reactive power



Bruce Mahrenholz,
 Director North American Certification Program
 UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL.
 For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>.



Page 4 of 4