



Date: April 1, 2024

Mr. Sangam Baligar  
Enphase Energy Inc  
1420 N McDowell Blvd  
Petaluma, CA, 94954-6515  
US

Dear Mr. Baligar,

The Enphase Battery Energy Storage System(BESS)—IQBATTERY-5P-1P-NA—is Certified to UL9540 and Listed under controlled UL File E488100. It contains the Battery Cell Pack, BMS, and Inverters.

The Inverters [IQ8D-BAT-240/IQ8D-BAT] are Certified to UL1741 SA/SB [IEEE1547:2018 and IEEE 1547.1:2020] and separately Listed and controlled by UL in File E341165. Additionally, the Inverter Firmware/software is evaluated to UL 1998 and is also captured in File E341165.

The Battery Cell Packs [EHE-002, EHE-002 Rev 02, and ZE21156-01] in the BESS are separately evaluated to UL1973 and controlled by UL in File MH62947. The safety critical hardware and software in the BMS of these cell packs are also evaluated to UL 60730-1.

Should you have any questions or comments concerning the above, please feel free to contact the undersigned.

Sincerely,

Holly Tribuzio

Senior Project Engineer

Holly.Tribuzio@ul.com

Reviewed by:'

Marvin Montenegro

Engineering Manager

Marvin.D.Montenegro@ul.com

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL Solutions) or any authorized licensee of UL Solutions.