Certificate Number: AZ 69027020

Page: 0001



CERTIFICATE OF SUITABILITY

Authorised marking: TUV-027020-E

TÜV Rheinland Australia Pty Ltd "Electrical Product Safety Certification (EPSC) Scheme", accredited by JAS-ANZ in accordance with ISO/IEC 17065, has issued this certificate under JAS-ANZ accreditation. The electrical equipment described hereunder has been evaluated and found to be electrically safe at the time of certification and met the minimum safety requirements contained in Australian Standard AS/NZS 3820 as of current. It is a requirement that all equipment supplied under this certificate shall be identical to the equipment as certified. The certificate holder may affix the above mentioned authorised marking on the product.

CERTIFICATE HOLDER: Enphase Energy Inc

> 47281 Bayside Pkwy, Fremont CA 94538

USA

DESCRIPTION OF EQUIPMENT

Declared class: Non-declared

Multimode Battery Inverter **Product:**

Trade Name / Manufacturer: ENPHASE

Model Number: B05-T02-ROW00-1-2

Ratings refer to Continuation Sheets 1 for details Ratings:

Remark: The product shall be used together with IQ System

Controller SC100G-M230ROWC

AS/NZS 4777.2:2020+A1 Standard:

> IEC 62477-1:2012+A1 IEC 62109-2:2011 IEC 62109-1:2010

Issue Date: 27/04/2023 **Expiry Date:** 27/04/2028

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

www.ias-anz.org\register

JAS-ANZ

Grant Li

TUV Rheinland Australia Pty Ltd 182 Dougharty Road, Heidelberg West VIC 3081

Phone: +61 (3) 9450 1400 Email: certification@au.tuv.com Website: www.au.tuv.com

Certificate Number:

AZ 69027020

Page: 0002



CERTIFICATE OF SUITABILITY

Authorised marking: TUV-027020-E

CONTINUATION SHEET 1

Description of Equipment

Ratings:

Input / Output Voltage and Frequency: 230V ac, 50Hz

Rated Input / output current: 16.7A

Rated Input / output apparent power:, 3.84kVA
Output power factor: -1 to 0 to +1 (off grid)
Output power factor: -0.8 to 0 to +0.8 (grid tied)

Protection: IP55, PD3, OVC III,

Ambient temperature: -20°C to +50°C charging,

20°C to +55°C discharging

Issue Date: 27/04/2023 Expiry Date: 27/04/2028

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

Grant Li

JAS-ANZ

www.jas-anz.org\register

TUV Rheinland Australia Pty Ltd 182 Dougharty Road, Heidelberg West VIC 3081

Phone: +61 (3) 9450 1400 Email: certification@au.tuv.com Website: www.au.tuv.com