



A P P R O V A L S ®

Certificate of Suitability

Certificate No.: SAA180938

Certificate Holder: Enphase Energy New Zealand Limited
1 Treffers Road,
Wigram, Christchurch 8042
New Zealand

Class Description: Non-Declared
Product Description: Network Relay Switch (NSR)
Brand Name: Enphase Energy
Model No.: Q-RELAY-1P-INT
Markings: 230-240V 50Hz 10VA
Max current: 20A
Operating temperature: -40°C to 50°C
Standard: AS 61010.1:2003
Conditions: Nil

Certification Mark: SAA180938 or RCM

Date First Registered: 13 April 2018
Date of Expiry: 13 April 2023

For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 13-04-18 180938/1