



A P P R O V A L S ®

Certificate of Suitability

Certificate No.: SAA181765

Certificate Holder: Enphase Energy New Zealand Limited
1 Treffers Road,
Wigram, Christchurch 8042
New Zealand

Class Description: Non-Declared
Product Description: Network Relay Switch
(Network System Relay [NSR], DIN rail-mounted)

Brand Name: Enphase

Model No.: Q-RELAY-3P-INT

Markings: 230-240Vac 50Hz, Max current 25A

Operating temperature: -40°C to +50°C, IP20

Standard: AS/NZS 61010.1:2003

Conditions: Nil

Certification Mark: SAA181765 or RCM

Date First Registered: 6 July 2018

Date of Expiry: 6 July 2023

For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd certifies that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au



Issued: 06-07-18 181765/1