

Declaration of Conformity

Certificate Number: DOC_20170801_02
Report Reference: P20170801_02
Issue Date: 15 December 2017

Issued to: **Enphase Energy Inc.**
1420 N.McDowell Blvd. Petaluma, CA 94954-6515

This is to certify that representative samples of

Utility-interconnected photovoltaic inverters with advanced grid functions

Models:
IQ7PLUS-72-X-Y-Z
IQ7-60-X-Y-Z

Have been investigated by Enphase Energy NZ Ltd, IANZ accreditation no: 1273 in accordance with the Standard(s) indicated.

Standard(s) IEC 62109-2:2011– Safety of power converters for use in photovoltaic power systems - Part 2: Particular requirements for inverters.

See Enphase Energy NZ Ltd test report P20170801_02 for full test data.

Additional Information:

Model nomenclature details:
X = 2 or 5 (2 = Multicontact PV connector, 5 = Amphenol PV connector)
Y = blank or ACM (X marking not required)
Z = blank or any letter for country of intended installation (eg: US for North America, INT for International)

This document certifies that representative samples of the products specified in this certificate were tested and comply with IEC 62109-2:2011.

Prepared by:



Robin Kidson
Enphase Energy

Signed on behalf of Enphase Energy, Inc.

15 December 2017
Christchurch, New Zealand



Manuel Shimasaki
Director, Global Certification

Declaration of Conformity

Certificate Number: DOC_20170801_02
Report Reference: P20170801_02
Issue Date: 15 December 2017

Inverter Ratings - Output	Model: IQ7PLUS-72-X-Y-Z
Nominal output voltage (V AC)	230 V
Normal output frequency (Hz)	50 Hz
Rated output current (A AC)	1.26 A
Rated output (VA)	290 VA (290W)
Maximum air ambient	65 °C

Inverter Ratings - Output	Model: IQ7-60-X-Y-Z
Nominal output voltage (V AC)	230 V
Normal output frequency (Hz)	50 Hz
Rated output current (A AC)	1.04 A
Rated output (VA)	240 VA (240 W)
Maximum air ambient	65 °C



Signed on behalf of Enphase Energy, Inc.

15 December 2017
Christchurch, New Zealand



Manuel Shimasaki
Director, Global Certification