

Harmoniques du micro-onduleur IQ8.

jeudi 12 octobre 2023

Résultats des harmoniques demandés jusqu'au 50ème.

D'ordre	Courant harmonique % de In	D'ordre	Courant harmonique % de In
2	0.121%	3	0.842%
4	0.100%	5	0.695%
6	0.134%	7	0.575%
8	0.104%	9	0.389%
10	0.116%	11	0.348%
12	0.111%	13	0.231%
14	0.101%	15	0.179%
16	0.101%	17	0.070%
18	0.106%	19	0.081%
20	0.094%	21	0.036%
22	0.083%	23	0.062%
24	0.090%	25	0.045%
26	0.077%	27	0.078%
28	0.076%	29	0.069%
30	0.074%	31	0.094%
32	0.067%	33	0.069%
34	0.069%	35	0.083%
36	0.054%	37	0.062%
38	0.054%	39	0.080%
40	0.052%	41	0.037%
42	0.046%	43	0.063%
44	0.045%	45	0.030%
46	0.044%	47	0.048%
48	0.033%	49	0.033%
50	0.030%		

Cordialement



Daniel Keis

Conformité – Performance du responsable technique